



## MANUAL

Typ/type eb  
IBExU 23 ATEX 1068 X  
IECEx IBE 23.0026X

Typ/type ec  
IBExU 23 ATEX B009 X  
IECEx IBE 23.0028X

Explosionsgeschützte  
LED-Langfeldleuchte  
Luminaires LED longitudinaux  
antidéflagrants  
Explosionproof LED linear  
luminaires  
Typ/type eb 851 / eb 852  
ec 851 / ec 852











**2.13 Mögliche Anzahl Leuchten pro Leitungsschutzschalter\*:**


Typ	B 10 A	B 16 A	C 10 A	C 16 A
e* 85* ..	11	19	19	32

\*) Typische Werte; mögl. Abweichungen abhängig von Fabrikat, Leitungsimpedanz u. Temperatur

**2.14 Durchgangsverdahrtung**

Mögliche Einschränkungen beachten (siehe Typenschild)

**2.15 Abmessungen (alle Masse in mm)**



**Das Durchbohren des Leuchtengehäuses zur Befestigung der Leuchte ist nicht zulässig!**

**Il n'est pas permis de percer le boîtier du luminaire pour le fixer !**

**2.13 Nombre possible de luminaires par disjoncteur\*:**


Typ	B 10 A	B 16 A	C 10 A	C 16 A
e* 85* ..	11	19	19	32

\*) Valeurs typiques; peut varier en fonction du modèle, de l'impédance et de la température

**2.14 Câblage traversant**

Tenir compte des restrictions éventuelles (voir la plaque signalétique)

**2.15 Dimensions (toutes les dimensions en mm)**



**Drilling of the luminaire enclosure for fixing the enclosure is not permitted!**





## 4.1 Öffnen der Leuchte

Äussere Klammerver-schlüsse von Hand öffnen.



Auf jeder Längsseite befindet sich in der Mitte ein Sicherheitsverschluss, der nur mit einem Schlitzschraube dreher (3-6 mm Klingenbreite) geöffnet werden kann (siehe Darstellung).

Une fermeture de sécurité se trouve au milieu du côté long, elle ne peut être ouverte qu'avec un tournevis plat (lame d'une largeur de 3 à 6 mm, voir l'illustration).

Leuchtenglas mit darin eingebautem Reflektor vom Leuchtengehäuse nehmen.

## 4.2 Elektrischer Anschluss

- 1 der Leuchte beigelegte Ex-Kabelverschraubungen bzw. Ex-Verschlusschraube mit Hilfe der Gegenmuttern im Leuchtengehäuse montieren (Drehmoment siehe Kapitel 2, Techn. Daten).
- 2 Nach Montage des Leuchtengehäuses die Anschlussleitung durch die Ex-Kabelverschraubung einführen. Eine ggf. eingelegte Staubschutzscheibe ist zuvor zu entfernen.
- 3 Überwurfmutter der Ex-Kabelverschraubung anziehen (Drehmoment siehe Kapitel 2, Technische Daten).
- 4 Leiter der Anschlussleitung entsprechend der Beschriftung anschliessen.

**Bei höheren Umgebungstemperaturen besteht nur eingeschränkte bzw. keine Möglichkeit zur Durchgangsverdrahtung. Die hierzu gemachten Angaben auf dem Typenschild der Leuchte sind zu beachten!**

**Die auf dem Typenschild angegebenen Nenn-daten und Hinweise müssen berücksichtigt werden.**


## 4.1 Ouverture du luminaire

Ouvrir à la main les fermetures externes à agrafes

Sicherheitsverschluss / Fermeture de sécurité

## 4.1 Opening luminaire

Open external clip fasteners by hand.



Each long side features a safety catch in the middle. This can only be opened with a slot screwdriver (width of tip 3-6 mm) (see illustration).

Remove the luminaire glass with the built-in reflector from the luminaire housing.

## 4.2 Electrical connection

- 1 Fit the enclosed Ex cable glands and Ex blanking plug into the luminaire housing using the locknuts (See Chapter 2, Technical Data, for torque).
- 2 After mounting the luminaire housing, feed the connection cable through the Ex cable gland. If used, the dust protection washer shall be removed first.
- 3 Tighten the cap nut on the Ex cable gland (See Chapter 2, Technical Data, for torque).
- 4 Connect the conductors of the connection cable in accordance with the marking.

**In the event of higher ambient temperatures, there is only a limited or no possibility of using a through-wiring. The details relating to this on the type label of the luminaire shall be observed!**

**The design data stated on the rating plate including remarks must always be taken into account.**

**By using suitable measures, such as a strain relief, it is necessary to ensure that the con-**



Durch geeignete Massnahmen wie einer Zugentlastung muss sichergestellt werden, dass die Anschlussleitung ausserhalb der Leuchte so fixiert ist, dass sie vor Verdrehen geschützt ist und keine Zugkräfte auf die Leitung und die Ex-Kabelverschraubung einwirken!

Nicht zur Leitungseinführung verwendete Ex-Kabelverschraubungen müssen mit beigefügtem Verschlussstopfen abgedichtet werden! Eine ggf. eingelegte Staubschutzscheibe ist zuvor zu entfernen.

Der Aussendurchmesser der Anschlussleitung muss dem Dichtbereich der Ex-Kabelverschraubung entsprechen!

Beim Abmanteln bzw. Abisolieren der Anschlussleitung dürfen die Leiter nicht beschädigt werden!

Beim Abisolieren der Leiterenden ist auf korrekte Abisolierlänge zu achten!

Es ist unbedingt darauf zu achten, dass der blaue Teil der angeschlossenen Leiter vollständig in die Anschlussklemme eingeführt und keine Leitungsisolation untergeklemmt ist!

#### 4.3 Schliessen der Leuchte

- 1 Leuchtenglas mit darin eingebautem Reflektor auf das Leuchtengehäuse aufsetzen.
- 2 Klammerverschlüsse in das Leuchtenglas einhängen und verriegeln.
- 3 Nach dem Schliessen der Leuchte ist zu kontrollieren, dass das Dichtungsprofil die Leuchte einwandfrei abdichtet.

#### 5. Inbetriebnahme

Für das Errichten/Betreiben sind die allgemein anerkannten Regeln der Technik EN 60079-14:2014 «Projektierung, Auswahl und Errichtung elektrischer Anlagen», nationale Vorschriften und diese Betriebsanleitung massgebend.

Die auf dem Typenschild angegebenen Nendaten und Hinweise müssen berücksichtigt werden.

*Il faut s'assurer par des mesures appropriées, telles qu'un soulagement de traction, que le câble de raccordement est fixé hors du luminaire de sorte qu'il soit protégé des torsions et qu'aucune force de traction n'agisse sur le câble et la presse-étoupe Ex !*

*Les presse-étoupes Ex qui ne sont pas utilisés pour l'introduction des câbles doivent être refermés avec les bouchons fournis ! Le cas échéant, il faut d'abord retirer la rondelle de protection contre la poussière éventuellement présente.*

*Le diamètre externe du câble de raccordement doit correspondre au domaine d'étanchéité du presse-étoupe Ex !*

*Les conducteurs ne doivent pas être endommagés lors du dénudage du câble de raccordement !*

*Lors du dénudage des conducteurs, il faut veiller à respecter la bonne longueur !*

*Il est impératif de veiller à ce que la partie nue du conducteur soit entièrement introduite dans la borne et que l'isolant ne le soit pas !*

#### 4.3 Fermeture du boîtier

- 1 Placer le verre du luminaire avec le réflecteur intégré sur le boîtier.
- 2 Accrocher et bloquer les fermetures à crampons dans le verre du luminaire.
- 3 Après la fermeture du luminaire, il faut contrôler que le profilé assure une étanchéité parfaite du luminaire.

#### 5. Mise en service

*Les règles techniques généralement reconnues de la norme EN 60079-14:2014 «Conception, sélection et construction des installations électriques», les prescriptions nationales et les présentes instructions d'utilisation sont déterminantes pour la mise en place et l'exploitation.*

*Les valeurs nominales figurant sur la plaque signalétique y compris les remarques doivent être prises en considération.*

*nection cable outside the enclosure is fixed in such a way that it is protected against twisting and that there are no tensile forces acting on the cable and the Ex cable gland!*

*Any Ex cable glands that are not being used for feeding in cables shall be sealed with the enclosed blanking element! If used, the dust protection washer shall be removed first.*

*The external diameter of the connection cable must correspond with the sealing area of the Ex cable gland!*

*The conductors must not be damaged when stripping the connection cable!*

*When stripping conductor ends, it is necessary to ensure the correct stripping length!*

*It is essential to ensure that the bare part of the connected conductors is fed fully into the connection terminal and that none of the conductor insulation is pinched underneath it!*



#### 4.3 Closing luminaire

- 1 Place the luminaire glass with built-in reflector onto the luminaire housing.
- 2 Hook the clip fasteners into the glass and latch securely.
- 3 After closing, check the luminaire to ensure that the sealing profile seals properly.

#### 5. Putting into operation


*The generally recognized rules of engineering, IEC 60079-14:2013 “Electrical installations design, selection and erection”, national regulations and the instructions set out in this manual apply for the installation and operation.*

*The design data stated on the rating plate including remarks must always be taken into account.*



Bevor die explosionsgeschützte Leuchte in Betrieb genommen wird, muss sichergestellt werden dass:

- die Leuchte vorschriftsmässig und in der vorgeschriebenen Gebrauchslage montiert wurde.
- die Ex-Kabelverschraubungen bzw. Ex-Verschlusschrauben ordnungsgemäss in das Leuchtengehäuse eingeschraubt sind (Drehmoment siehe Kapitel 2, Technische Daten).
- die Überwurfmutter der Ex-Kabelverschraubung ordnungsgemäss angezogen ist (Drehmoment siehe Kapitel 2, Technische Daten).
- die Anschlussleitung ordnungsgemäss installiert und keinen Zugkräften ausgesetzt ist.
- der blanke Teil der angeschlossenen Leiter vollständig in die Anschlussklemme eingeführt ist und die Isolation der Leiter nicht mit untergeklemmt ist.
- die Leuchte ordnungsgemäss verschlossen ist.
- die Dichtungen ordnungsgemäss abdichten.
- die Leuchte nicht beschädigt ist.



### 5.1 Zur Beachtung bei der Isolationsprüfung


Zur Messung des Isolations-Widerstandes darf die Prüfspannung nur zwischen Außenleiter und Schutzleiter bzw. Neutralleiter und Schutzleiter angelegt werden.

Nach abgeschlossener Isolationsprüfung ist die einwandfreie Leiterverbindung zwischen Netz und Beleuchtungsanlage wieder herzustellen.

Vor Inbetriebnahme ist der feste Anschluss des Neutralleiters sicherzustellen, um das Vorschaltgerät durch unzulässige Überspannung bei unsymmetrischer Netzbelastrung nicht zu schädigen (siehe hierzu Abschnitt 5.2).

Before putting the explosionproof luminaire into operation, it is necessary to ensure that:

- the luminaire has been installed correctly and in the given operating position.
- the Ex cable glands or Ex blanking plugs have been screwed into the luminaire housing correctly (see Chapter 2, Technical Data for torque).
- The cap nut of the Ex cable gland has been tightened down (see Chapter 2, Technical Data for torque).
- the connection cable has been installed correctly and that it is not subjected to any tensile forces.
- That the bare part of the connected conductors is fed fully into the connection terminal and that none of the conductor insulation is pinched underneath it.
- the luminaire has been closed correctly.
- the seals seal properly.
- the luminaire is not damaged.



### 5.1 To be observed during the insulation test


When measuring the insulation resistance, the test voltage shall only be applied between the external conductor and the PE conductor or the neutral conductor and the PE conductor.

After completion of the insulation test, the proper connection of the cable connection between the mains and the lighting installation shall be restored. Before putting the luminaire into operation, it is necessary to ensure the firm connection of the neutral conductor so that the ballast is not damaged by an inadmissible overvoltage due to an asymmetric mains load (see Clause 5.2).

### 5.2 Betriebsgerät im 3-Phasen-Betrieb

Die unten abgebildete Darstellung zeigt die Verdrahtung bei Leuchten bzw. Leuchtengruppen in 3-Phasen-Schaltung bei gemeinsamem N-Leiter (Neutralleiter).

Wird bei anliegender Spannung der gemeinsame Neutralleiter unterbrochen, so können die Leuchten bzw. Leuchtengruppen an unzulässig hoher Spannung liegen und dadurch die Betriebsgeräte zerstört werden.



### 6. Inspektion, Wartung und Instandhaltung

*Die für die Inspektion, die Wartung und die Instandsetzung geltenden Bestimmungen der EN 60079-17, «Prüfung und Instandhaltung elektrischer Anlagen in explosionsgefährdeten Bereichen», sind einzuhalten. Im Rahmen der Inspektionen und der Wartung sind vor allem Teile zu prüfen, von denen die Zündschutzart abhängt.*

Es dürfen grundsätzlich nur Originalersatzteile des Herstellers eingesetzt werden.

#### 6.1 Qualifikation

Die Prüfung, die Wartung und die Instandsetzung der Anlagen darf nur von erfahrenem Personal ausgeführt werden, dem bei der Ausbildung auch Kenntnisse über die verschiedenen Zündschutzarten und Installationsverfahren, einschlägigen Regeln und Vorschriften sowie die allgemeinen Grundsätze der Bereichseinteilung vermittelt wurden. Eine angemessene Weiterbildung oder Schulung ist für das Personal regelmäßig durchzuführen.

excessives en raison de charges asymétriques (voir à ce sujet la section 5.2).

### 5.2 Équipement en mode triphasé


L'illustration ci-dessous montre la connexion de luminaires et de groupes de luminaires dans des circuits triphasés avec un conducteur neutre commun (conducteur N).

En cas de coupure du conducteur neutre commun alors que le circuit est sous tension, les luminaires ou groupes de luminaires peuvent être exposés à des tensions excessives et l'équipement peut être endommagé.

### 5.2 Operating unit in a 3-phase circuit

The following diagrams show the wiring for luminaires or groups of luminaires in a 3-phase circuit with a common N conductor (neutral conductor).

If, when the voltage is applied, the common neutral conductor is interrupted, an inadmissibly high voltage can be applied to the luminaires or groups of luminaires and, as a result, the operating units can be destroyed.



### 6. Inspection, servicing and maintenance

*When carrying out inspections, servicing or maintenance work, the valid provisions of IEC 60079-17 «Electrical installations inspection and maintenance of electrical installations in explosive atmospheres» shall be observed. During servicing, it is particularly important to check those components upon which the type of protection depends.*

Only original spare parts from the manufacturer may be used.

#### 6.1 Qualifications

Le contrôle, la maintenance et l'entretien des installations ne doivent être réalisés que par des personnes expérimentées qui ont aussi reçu, au cours de leur formation, des connaissances sur les différents modes de protection et procédures d'installation, les règles et les prescriptions pertinentes ainsi que les principes généraux de la classification des zones. Le personnel doit suivre régulièrement une formation ou un perfectionnement approprié.

En principe, seules des pièces de rechange d'origine du fabricant peuvent être utilisées.

#### 6.1 Qualifications

The testing, servicing and maintenance of the installations may only be carried out by experienced personnel that has been instructed regarding the various types of explosion protection and installation methods, as well as in the relevant rules and regulations and the general principles for the classification of areas. An appropriate further training or schooling of personnel shall be carried out on a regular basis.





dig die Leuchte regelmässig von Staubablagerungen zu befreien. Bei Staubschichten, deren Dicke 5 mm übersteigen kann, ist sicherzustellen, dass die Oberflächentemperatur der Leuchte die maximal zulässige Oberflächentemperatur für den vorhandenen Staub unter Berücksichtigung der Staubschichtdicke nicht überschreitet. Keinesfalls darf die Dicke einer Staubschicht 50 mm überschreiten.

#### 6.5 Regelmässige Wartungsarbeiten

- Hinweise in Kapitel 6.2 beachten!

Explosionsgeschützte Leuchten sind nach den nationalen Bestimmungen des Einsatzlandes regelmäßig zu warten, wobei hier besonders auf die Teile hingewiesen sei, von denen die Zündschutzart abhängt. Folgendes muss sorgfältig überprüft werden:

- Leuchtenglas, Leuchtengehäuse und Dichtungen auf Beschädigung.
- Ex-Kabelverschraubungen und Ex-Verschlusschrauben auf festen Sitz und Dichtheit (Drehmoment siehe Kapitel 2, Technische Daten).
- alle Kunststoffteile im Inneren der Leuchte auf Verfärbung, Verformung und Beschädigung.
- den festen Sitz der Leiter und den Zustand der Isolation.
- dass die Leuchte ordnungsgemäss und dicht verschlossen ist.

#### 7. Entsorgung

Bei der Entsorgung der Leuchten sind die jeweils geltenden nationalen Abfallbeseitigungsvorschriften zu beachten.

téristiques d'isolants thermiques et raccourcissent en conséquence la durée de vie du luminaire. Il est donc nécessaire de dépoussiérer régulièrement le luminaire. Si la couche de poussière est supérieure à 5 mm, il faut s'assurer que la température de la surface du luminaire ne dépasse pas la température maximale autorisée pour la poussière en question en prenant en compte son épaisseur. L'épaisseur de la couche de poussière ne doit en aucun cas dépasser les 50 mm.

#### 6.5 Travaux de maintenance réguliers

- Tenir compte des indications fournies au chapitre 6.2!

Les luminaires antidéflagrants doivent être entretenus de façon régulière en suivant les dispositions nationales du pays d'utilisation en accordant une attention particulière aux éléments dont dépend l'indice de protection. Les points suivants doivent être contrôlés avec soin:

- la présence de détériorations sur le verre et le boîtier du luminaire, ainsi que sur les joints;
- la stabilité et l'étanchéité des presse-étoupes et des vis (voir le chapitre 2 Données techniques pour le couple);
- la décoloration, la déformation et la détérioration de l'ensemble des éléments en plastique à l'intérieur du luminaire;
- la fixation stable des conducteurs et l'état de l'isolation;
- la fermeture correcte et étanche du luminaire.

#### 7. Élimination

Lors de l'élimination des lampes, les prescriptions nationales applicables devront être respectées.

more than 5 mm thick, it is necessary to ensure that the surface temperature of the luminaire does not exceed the maximum permissible surface temperature for the existing dust taking the layer thickness into consideration. The thickness of a layer of dust must not exceed 50 mm under any circumstances.

#### 6.5 Regular servicing

- Observe instructions in Chapter 6.2!

Explosionproof luminaires shall be serviced regularly in accordance with the national regulations of the country of operation, whereby here special attention is drawn on parts on which the explosion protection depends. The following shall be checked carefully:

- luminaire glass, housing and seals for damage.
- Ex cable glands and Ex blanking plugs for a firm fit and tightness (see Chapter 2, Technical Data for torques).
- all plastic parts inside the housing for discolouration, deformation and damage
- the secure fit of the conductors and the condition of the insulation.
- that the luminaire has been closed correctly and tightly.

#### 7. Disposal

When finally disposing of the luminaire the national end-of-life directive applying to this category of hardware must be complied with.



**IBExU Institut für Sicherheitstechnik GmbH**  
An-Institut der TU Bergakademie Freiberg

**[1] EU-TYPE EXAMINATION CERTIFICATE - Translation**

**[2]** Equipment or protective systems intended for use in potentially explosive atmospheres, Directive 2014/34/EU

**[3]** EU-type examination certificate number **IBExU23ATEX1068 X | Issue 0**

**[4]** Product: **Explosionproof LED linear luminaire**  
Type: eb 851 and eb 852

**[5]** Manufacturer: **thuba Ltd.**

**[6]** Address: **Stockbrunnrain 9  
4123 Allschwil  
SWITZERLAND**

**[7]** This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

**[8]** IBExU Institut für Sicherheitstechnik GmbH, notified body number 0637 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the essential health and safety requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential test report IB-23-3-0031.

**[9]** Compliance with the essential health and safety requirements has been assured by compliance with: EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-5:2015, EN IEC 60079-7:2015/A1:2018, EN 60079-11:2012, EN 60079-18:2015/A1:2017 and EN 60079-31:2014 except in respect of those requirements listed at item [18] of the schedule.

**[10]** If the sign "X" is placed after the certificate number, it indicates that the product is subject to the specific conditions of use specified in the schedule to this certificate.


**[11]** This EU-type examination certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

**[12]** The marking of the product shall include the following:

II 2G Ex eb mb q IIC T4 Gb  
 II 2G Ex db eb mb q IIC T4 Gb  
 II 2G Ex eb ib mb q IIC T4 Gb  
 II 2G Ex db eb ib mb q IIC T4 Gb  
 II 2D Ex tb IIIC T80 °C Db

-40 °C ≤ T<sub>a</sub> ≤ +70 °C (maximum values)

IBExU Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7  
09599 Freiberg, GERMANY

By order  
  
Dr.-Ing. P. Cimalla

**IBExU**  
Institut für  
Sicherheits-  
technik  
GmbH  
Seal Nr. 0637  
(notified body number 0637)

Tel: + 49 (0) 37 31 / 38 05 0  
Fax: + 49 (0) 37 31 / 38 05 10

Certificates without signature and seal are not valid. Certificates may only be duplicated completely and unchanged. In case of dispute, the German text shall prevail.

Freiberg, 2023-10-18

Page 1/2  
IBExU23ATEX1068 X | 0

FB106100 | 1

**IBExU Institut für Sicherheitstechnik GmbH**  
An-Institut der TU Bergakademie Freiberg

**[13] Schedule**

**[14] Certificate number IBExU23ATEX1068 X | Issue 0**

**[15] Description of product**  
The LED linear luminaires type eb 851 and eb 852 are used to illuminate factory shops and stores. It is suitable for the operation in hazardous areas requiring equipment of category 2G or 2D. The luminaire consists of the polyester enclosure with fasteners made of stainless steel, the reflector with the assembled LED boards, terminals and LED control gear as well as a light-transmitting cover made of polycarbonate.

**Technical data:**

- rated voltage:	220...250 V AC (50...60 Hz) or 176...275 V DC
- input power:	maximum 75 W
- through wiring/looping:	up to 12 x ≥ 2.5 mm <sup>2</sup> (max. 4 x 16 A)
- ambient temperature range:	-40 °C up to +70 °C

These values are maximum values. The actual values are limited by the built-in components and electrical parameter. The manufacturer specifies the rated values in the context of these limiting values and ensures compliance with the maximum surface temperature of the equipment and the permissible operating temperature of the components. Through-wiring, selection of the cable and cable gland may be restricted in some types of the luminaire.

**[16] Test report**  
The test results are recorded in the confidential test report IB-23-3-0031 of 2023-09-18. The test documents are part of the test report and they are listed there.

**Summary of the test results**  
The LED linear luminaire type eb 851 and eb 852 fulfils the requirements of explosion protection for Equipment Group II, Category 2G, type of protection increased safety „eb“ in combination with encapsulation “mb“, powder filling “q“ as well as flameproof enclosure “db“ and intrinsic safety “ib“ as well as Category 2D in type protection by enclosure “tb“.


**[17] Specific conditions of use**

- The plastic housing has to be protected against intense electrostatic charging processes. Cleaning is permitted only with a damp cloth.

**[18] Essential health and safety requirements**  
In addition to the essential health and safety requirements (EHSRs) covered by the standards listed at item [9], the following are considered relevant to this product, and conformity is demonstrated in the test report:  
None

**[19] Drawings and Documents**  
The documents are listed in the test report.

IBExU Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7  
09599 Freiberg, GERMANY

By order  
  
Dr.-Ing. P. Cimalla

Freiberg, 2023-10-18

Page 2/2  
IBExU23ATEX1068 X | 0

FB106100 | 1

**IBExU Institut für Sicherheitstechnik GmbH**  
An-Institut der TU Bergakademie Freiberg

**[1] BAUMUSTERPRÜFBESCHEINIGUNG**

**[2]** für nicht-elektrische Produkte der Gerätekategorien I und II,  
Gerätekategorien M2 und 2 sowie Produkte der Gerätekategorie 3

**[3]** Baumusterprüfbescheinigung Nummer **IBExU23ATEXB009 X | Ausgabe 0**

**[4]** Produkt: **LED Langfeldleuchte und LED Notleuchte**  
Typ: ec 851, ec 852 und ec 854 N

**[5]** Hersteller: **thuba Ltd**

**[6]** Anschrift: **Stockbrunnenrain 9  
4123 Aeschwil  
SWITZERLAND**

**[7]** Dieses Produkt sowie die verschiedenen zulässigen Ausführungen sind in der Anlage zu dieser Bescheinigung sowie den darin aufgeführten Unterlagen festgelegt.

**[8]** IBExU Institut für Sicherheitstechnik GmbH bestätigt, dass dieses Produkt die wesentlichen Sicherheits- und Gesundheitsanforderungen für die Konzeption und den Bau von Produkten zur bestimmungsgemäßen Verwendung in explosionsgefährdeten Bereichen aus Anhang II der Richtlinie 2014/34/EU des Europäischen Parlaments und des Rates vom 26. Februar 2014 erfüllt.

Die Untersuchungs- und Prüfergebnisse werden in dem vertraulichen Prüfbericht IB-23-3-0033 festgehalten.

**[9]** Die Beachtung der wesentlichen Sicherheits- und Gesundheitsanforderungen wurde in Übereinstimmung mit folgenden Normen gewährleistet:  
EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-5:2015, EN IEC 60079-7:2015/A1:2018,  
EN 60079-11:2012, EN 60079-18:2015/A1:2017 und EN 60079-31:2014  
Hier von ausgenommen sind jene Anforderungen, die unter Punkt [18] der Anlage aufgelistet werden.

**[10]** Ein „X“ oder „U“ hinter der Bescheinigungsnummer weist darauf hin, dass das Produkt den besonderen Bedingungen für die Verwendung unterliegt, die in der Anlage zu dieser Bescheinigung festgehalten sind.

**[11]** Diese Baumusterprüfbescheinigung bezieht sich ausschließlich auf die Konzeption des angegebenen Produkts und nicht auf die Fertigung und Bereitstellung weiterer Produkte.

**[12]** Die Kennzeichnung des Produkts muss Folgendes beinhalten:

Typ ec 851 und ec 852

II 3G Ex ec IIC T4 Gc X  
 II 3G Ex ec q IIC T4 Gc X  
 II 3G Ex db ec IIC T4 Gc X  
 II 3G Ex ec lb mb IIC T4 Gc X  
 II 3D Ex tc IIIC T80 °C Dc X  
-40 °C ≤ Ta ≤ +65 °C (Maximalwerte)

Seite 1/4  
IBExU23ATEXB009 X | 0

FB106109 | 1


**IBExU Institut für Sicherheitstechnik GmbH**  
An-Institut der TU Bergakademie Freiberg

**Typ ec 854 N**

II 3G Ex ec IIC T4 Gc  
 II 3G Ex db ec IIC T4 Gc  
 II 3D Ex tc IIIC T80 °C Dc  
-30 °C ≤ Ta ≤ +55 °C (Maximalwerte)

IBExU Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7  
09599 Freiberg, GERMANY

**IBExU**  
Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7  
09599 Freiberg/Sachsen  
Telefon (03731) 3805-0  
Telex (03731) 38 05 10

Im Auftrag  
  
Dr.-Ing. P. Cimalla

- Stempel -

Bescheinigungen ohne Stempel und Unterschrift haben keine Gültigkeit.  
Bescheinigungen dürfen nur vollständig und unverändert vervielfältigt werden.

Freiberg, 24.11.2023

Seite 2/4  
IBExU23ATEXB009 X | 0

FB106109 | 1



**IBExU Institut für Sicherheitstechnik GmbH**  
An-Institut der TU Bergakademie Freiberg

[1] **TYPE EXAMINATION CERTIFICATE - Translation**

[2] for non-electrical products of equipment-groups I and II,  
equipment-categories M2 and 2 plus products of equipment-category 3

[3] Type examination certificate number **IBExU23ATEXB009 X | Issue 0**

[4] Product: **LED linear luminaires and LED emergency light fitting**  
Type: ec 851, ec 852 and ec 854 N

[5] Manufacturer: **thuba Ltd.**

[6] Address: **Stockbrunnenrain 9  
4123 Aeschwil  
SWITZERLAND**

[7] This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

[8] IBExU Institut für Sicherheitstechnik GmbH certifies that this product has been found to comply with the essential health and safety requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014.

The examination and test results are recorded in the confidential test report IB-23-3-0033.

[9] Compliance with the essential health and safety requirements has been assured by compliance with:  
EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-5:2015, EN IEC 60079-7:2015/A1:2018,  
EN 60079-11:2012, EN 60079-18:2015/A1:2017 and EN 60079-31:2014  
except in respect of those requirements listed at item [18] of the schedule.

[10] If the sign "X" or "U" is placed after the certificate number, it indicates that the product is subject to the specific conditions of use specified in the schedule to this certificate.

[11] This type examination certificate relates only to the design of the specified equipment and not to specific items of equipment subsequently manufactured or supplied.

[12] The marking of the product shall include the following:

Type ec 851 and ec 852

II 3G Ex ec IIC T4 Gc X  
 II 3G Ex ec q IIC T4 Gc X  
 II 3G Ex db ec IIC T4 Gc X  
 II 3G Ex ec lb mb IIC T4 Gc X  
 II 3D Ex tc IIIC T80 °C Dc X  
-40 °C ≤ T<sub>a</sub> ≤ +65 °C (maximum values)

Page 1/4  
IBExU23ATEXB009 X | 0

FB106109 | 1

**IBExU Institut für Sicherheitstechnik GmbH**  
An-Institut der TU Bergakademie Freiberg

Type ec 854 N

II 3G Ex ec IIC T4 Gc X  
 II 3G Ex db ec IIC T4 Gc X  
 II 3D Ex tc IIIC T80 °C Dc X  
-30 °C ≤ T<sub>a</sub> ≤ +55 °C (maximum values)

IBExU Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7  
09599 Freiberg, GERMANY

By order  
  
Dr.-Ing. P. Cimalla

**IBExU**  
Institut für Sicherheitstechnik GmbH  
Fuchsmühlenweg 7  
09599 Freiberg/Sachsen  
Telefon (03731) 3805-0  
Telex (03731) 3805 10

Tel: + 49 (0) 37 31 / 38 05 0  
Fax: + 49 (0) 37 31 / 38 05 10

Certificates without signature and stamp are not valid. Certificates may only be duplicated completely and unchanged. In case of dispute, the German text shall prevail.

- Stamp -

Freiberg, 2023-11-24

Page 2/4  
IBExU23ATEXB009 X | 0

FB106109 | 1

**IBExU Institut für Sicherheitstechnik GmbH**  
An-Institut der TU Bergakademie Freiberg

[13] **Schedule**

[14] **Certificate number** IBExU23ATEXB009 X | Issue 0

[15] **Description of product**

The LED linear luminaires type ec 851, ec 852 and LED emergency light fitting type ec 854 N are used to illuminate factory and depot sites in areas with potentially gas and dust explosive requiring equipment of category 3G or 3D. The luminaire consists of a polyester enclosure with fasteners made of stainless steel, a reflector with assembled LED boards, LED control gear and terminals, as well as a light-transmitting cover made of polycarbonate.

LED emergency light fitting type ec 854 N provides an emergency light function. It uses an alternate LED control gear and a rechargeable and changeable battery pack in difference to ec 851 and ec 852. The battery pack is either in the housing or in a separate battery housing which is assembled to the side of the luminaire. Service and fault conditions are indicated by means of coloured LED which is inside the luminaire.

The output current for supplying the LED modules may be set by means of DALI interface.

Both types may be equipped with coloured LED.

Technical data:

- Rated voltage:
  - ec 851 and ec 852: 220 ... 240 V AC (50...60 Hz) or  
176 ... 275 V DC
  - ec 854 N: 220 ... 240 V AC (50...60 Hz)
- Input power: maximum 54 W (ec 851 and ec 852)  
maximum 41 W (ec 854 N)
- Battery: NiCd 6 V / 4 Ah  
NiCd 6 V / 1,6 Ah
- Through-wiring / looping: up to 12 x  $\geq 2.5 \text{ mm}^2$  (max. 4 x 16 A)
- Ambient temperature: -40 °C...+65 °C (Type ec 851 and ec 852)  
-30 °C...+55 °C (Type ec 854 N)

These values are maximum values. The actual values by the built-in components and electrical parameter. The manufacturer specifies the rated values in the context of these limiting values and ensures compliance with the maximum surface temperature of the equipment and the permissible operating temperature of the components. Through-wiring, selection of the cable and cable gland may be restricted in some types of the luminaire.

[16] **Test report**

The test results are recorded in the confidential test report IB-23-3-0033 of 2023-09-29.  
The test documents are part of the test report and they are listed there.

*Summary of the test results*

The LED linear luminaires type ec 851, ec 852 and LED emergency light fitting type ec 854 N fulfil the requirements of explosion protection for electrical equipment of Equipment Group II, Category 3G in type of protection increased safety "e" in combination with powder filling "q" or flameproof enclosure "d" or intrinsic safety "i" or encapsulation "m" for Explosion Group IIC and temperature class T4, as well as Category 3D in type of protection dust ignition protection by enclosure "t" for Explosion Group IIIC and a maximum surface temperature of 80 °C.

[17] **Specific conditions of use**

- \* The plastic housing has to be protected against intense electrostatic charging processes. Cleaning is permitted only with a damp cloth.

**IBExU Institut für Sicherheitstechnik GmbH**  
An-Institut der TU Bergakademie Freiberg

[18] **Essential health and safety requirements**

In addition to the essential health and safety requirements (EHSRs) covered by the standards listed at item [9], the following are considered relevant to this product, and conformity is demonstrated in the test report:  
None

[19] **Drawings and Documents**

The documents are listed in the test report.


IBExU Institut für Sicherheitstechnik GmbH  
Fuchsmühlweg 7  
09599 Freiberg, GERMANY

By order



Dr.-Ing. P. Cimalla

Freiberg, 2023-11-24



 **IECEx Certificate of Conformity**

Certificate No.: **IECEx IBE 23.0026X** Page 2 of 3  
 Date of issue: 2023-10-18 Issue No: 0

Manufacturer: **thuba Ltd.**  
 Stockbrunnenrain 9  
 4123 Allschwil  
**Switzerland**

Manufacturing locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

**STANDARDS :**  
 The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

<a href="#">IEC 60079-0:2017</a>	Explosive atmospheres - Part 0: Equipment - General requirements Edition:7.0
<a href="#">IEC 60079-1:2014</a>	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d" Edition:7.0
<a href="#">IEC 60079-11:2011</a>	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i" Edition:6.0
<a href="#">IEC 60079-18:2017</a>	Explosive atmospheres - Part 18: Protection by encapsulation "m" Edition:4.1
<a href="#">IEC 60079-31:2022</a>	Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure "t" Edition:3.0
<a href="#">IEC 60079-5:2015</a>	Explosive atmospheres –Part 5: Equipment protection by powder filling "q" Edition:4.0
<a href="#">IEC 60079-7:2017</a>	Explosive atmospheres - Part 7: Equipment protection by increased safety "e" Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

**TEST & ASSESSMENT REPORTS:**  
 A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:  
[DE/IBE/ExTR23.0024/00](#)

Quality Assessment Report:  
[DE/BVS/QAR13.0010/12](#)

 **IECEx Certificate of Conformity**

Certificate No.: **IECEx IBE 23.0026X** Page 3 of 3  
 Date of issue: 2023-10-18 Issue No: 0

**EQUIPMENT:**  
 Equipment and systems covered by this Certificate are as follows:

The LED linear luminaires type eb 851 and eb 852 are used to illuminate factory shops and stores. It is suitable for the operation in hazardous areas requiring equipment of EPL Gb or Db.

The luminaire consists of the polyester enclosure with fasteners made of stainless steel, the reflector with the assembled LED boards, terminals and LED control gear as well as a light-transmitting cover made of polycarbonate.

**Technical data:**

- rated voltage: ..250 V AC (50...60 Hz) or 176...275 V DC
- input power: maximum 75 W
- through wiring/looping: up to  $12 \times 2.5 \text{ mm}^2$  (max. 4 x 16 A)
- ambient temperature range: -40 °C up to +70 °C

These values are maximum values. The actual values are limited by the built-in components and electrical parameters. The manufacturer specifies the rated values in the context of these limiting values and ensures compliance with the maximum surface temperature of the equipment and the permissible operating temperature of the components. Through-wiring, selection of the cable and cable gland may be restricted in some types of the luminaire.

**SPECIFIC CONDITIONS OF USE: YES as shown below:**  
 The plastic housing has to be protected against intense electrostatic charging processes. Cleaning is permitted only with a damp cloth.

**IECEx Certificate of Conformity**

INTERNATIONAL ELECTROTECHNICAL COMMISSION  
IEC Certification System for Explosive Atmospheres  
for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.:	<b>IECEx IBE 23.0028X</b>	Page 1 of 3	<a href="#">Certificate history</a>
Status:	<b>Current</b>	Issue No. 0	
Date of Issue:	2023-11-24		
Applicant:	<b>thuba Ltd.</b> Stockbrunnenrain 9 4123 Allschwil <b>Switzerland</b>		
Equipment:	<b>Explosionproof LED linear luminaires and LED emergency light fitting type ec 851, ec 852 and ec 854 N</b>		
Optional accessory:			
Type of Protection:	<b>Increased safety, flameproof enclosure, powder filling, encapsulation, intrinsic safety, dust ignition protection by enclosure</b>		
Marking:	Type ec 851 and ec 852 Ex ec IIC T4 Gc Ex ec q IIC T4 Gc Ex db ec IIC T4 Gc Ex ec ib mb IIC T4 Gc Ex tc IIIC T80 °C Dc $-40^{\circ}\text{C} \leq T_a \leq +65^{\circ}\text{C}$ (maximum values)		
	Type ec 854 N Ex ec IIC T4 Gc Ex db ec IIC T4 Gc Ex tc IIIC T80 °C Dc $-30^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$ (maximum values)		
Approved for issue on behalf of the IECEx Certification Body:	<b>Dr.-Ing. Peter Cimalla</b>		
Position:	<b>Deputy Head of department Certification Body</b>		
Signature: (for printed version)			
Date: (for printed version)			
1. This certificate and schedule may only be reproduced in full. 2. This certificate is not transferable and remains the property of the issuing body. 3. The Status and authenticity of this certificate may be verified by visiting <a href="http://www.iecex.com">www.iecex.com</a> or use of this QR Code.			
<b>Certificate issued by:</b>		<b>IBExU</b>	
<b>IBExU Institut für Sicherheitstechnik GmbH</b> Fuchsmühlenweg 7 09599 Freiberg <b>Germany</b>			

**IECEx Certificate of Conformity**

Certificate No.: **IECEx IBE 23.0028X** Page 2 of 3  
Date of issue: 2023-11-24 Issue No. 0

Manufacturer: **thuba Ltd.**  
Stockbrunnenrain 9  
4123 Allschwil  
**Switzerland**

Manufacturing locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

**STANDARDS:**  
The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

<b>IEC 60079-0:2017</b> Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirements
<b>IEC 60079-1:2014</b> Edition:7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
<b>IEC 60079-11:2011</b> Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
<b>IEC 60079-18:2017</b> Edition:4.1	Explosive atmospheres - Part 18: Protection by encapsulation "m"
<b>IEC 60079-31:2022</b> Edition:3.0	Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure "t"
<b>IEC 60079-5:2015</b> Edition:4.0	Explosive atmospheres –Part 5: Equipment protection by powder filling "q"
<b>IEC 60079-7:2017</b> Edition:5.1	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

This Certificate does not indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

**TEST & ASSESSMENT REPORTS:**  
A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:  
**DE/IBE/ExTR23.0026/00**

Quality Assessment Report:  
**DE/BVS/QAR13.0010/12**

**IECEx Certificate of Conformity**

Certificate No.: IECEx IBE 23.0028X  
Page 3 of 3  
Date of issue: 2023-11-24  
Issue No: 0

**EQUIPMENT:**  
Equipment and systems covered by this Certificate are as follows:

The LED linear luminaires type ec 851, ec 852 and LED emergency light fitting type ec 854 N are used to illuminate factory and depot sites in areas with potentially gas and dust explosive atmospheres requiring equipment of EPL Gc or Dc. The luminaire consists of a polyester enclosure with fasteners made of stainless steel, a reflector with assembled LED boards, LED control gear and terminals, as well as a light-transmitting cover made of polycarbonate.

LED emergency light fitting type ec 854 N provides an emergency light function. It uses an alternate LED control gear and a rechargeable and changeable battery pack in difference to ec 851 and ec 852. The battery pack is either in the housing or in a separate battery housing which is assembled to the side of the luminaire. Service and fault conditions are indicated by means of coloured LED which is inside the luminaire.

The output current for supplying the LED modules may be set by means of DALI interface.

Both types may be equipped with coloured LED.

**Technical data:**

Rated voltage:  
ec 851 ac and ec 852: 220 ... 240 V AC (50...60 Hz) or 176 ... 275 V DC  
ec 854 N: 220 ... 240 V AC (50...60 Hz)

Input power:  
maximum 54 W (ec 851 and ec 852)  
maximum 41 W (ec 854 N)

Battery:  
NiCd 6 V / 4 Ah  
NiCd 6 V / 1.6 Ah

Through-wiring / looping:  
up to 12 x ≥ 2.5 mm<sup>2</sup> (max. 4 x 16 A)

Ambient temperature range:  
-40 °C...+65 °C (Type ec 851 and ec 852)  
-30 °C...+55 °C (Type ec 854 N)

These values are maximum values. The actual values by the built-in components and electrical parameter. The manufacturer specifies the rated values in the context of these limiting values and ensures compliance with the maximum surface temperature of the equipment and the permissible operating temperature of the components. Through-wiring, selection of the cable and cable gland may be restricted in some types of the luminaire.

**SPECIFIC CONDITIONS OF USE: YES as shown below:**  
The plastic housing has to be protected against intense charging processes. Cleaning is permitted only with a damp cloth.

# Your partner for internationally certified solutions in explosion protection

## Design and Production

### Explosionproof switchgear assemblies

Equipment protection level EPL Gb

- flameproof enclosure 'db'
- increased safety 'eb'
- pressurized enclosure 'pxb'

Equipment protection EPL level Gc

- increased safety 'ec'
- restricted breathing enclosure 'nR'
- pressurized enclosure 'pzc'

Equipment protection level EPL Db and Dc for areas at risk of dust explosions

- protection by enclosure 'tb', 'tc'
- pressurized enclosure 'pxb', 'pzc'

## Accessories

- digital displays
- disconnect amplifiers
- transmitter power packs
- safety barriers
- keyboard and mouse
- monitor
- industrial PC

## Lamps

Equipment protection level EPL Ga, Gb, Gc and EPL Da, Db, Dc

- LED hand lamps and tube lights 6 to 80 W
- LED tube lights for switchgear assemblies
- LED linear luminaires 18 to 58 W (also with integrated emergency lighting)
- flameproof LED-tubes (Replacement for fluorescent tubes)
- signal towers
- reflector lamps
- safety lighting
- flashing lamps
- boiler flange lamps

## Electric heaters for industrial applications

- heating of air and gases (up to 100 bar)
- heating of liquids
- reactor heating systems (HT installations)
- heating of solids
- special solutions

## Pipe and tank trace heating systems

- heating cables
    - heating cables with fixed resistors
    - mineral-insulated heating cables
    - self-limiting heating cables
  - site installation
  - temperature monitoring systems
    - thermostats and safety temperature limiters
    - electronic temperature controllers and safety cutouts
    - remote controls for temperature controller
  - resistance temperature detectors Pt-100
- Equipment protection level EPL Ga and Gb

## Installation material

- temporary bonding
- earth monitoring systems
- terminals and junction boxes
- motor protecting switches up to 63 A
- safety switches 10 to 180 A (indirect and direct tripping)
- plug-and-socket devices
- clean room power outlets
- control and indicating devices
- signalling device
- customized control stations
- cable reels (max. 3 flange sockets)
- cable glands
- fastening material

## Accredited inspection body (SIS 0145)

Extremely strict inspections are carried out to guarantee the correct operation and safety of installations in hazardous areas. We carry out both professional initial inspections and periodic inspections. These consist of a documentation and organisation check and a technical inspection.

## Service Facilities according to IECEx Scheme

As an IECEx Scheme service facility we are qualified to carry out repairs, overhauling and regeneration work all over the world – even on equipment from other manufacturers.



THE EXPLOSIONPROOFING COMPANY

**thuba Ltd.**  
**CH-4002 Basel**

Production:  
Stockbrunnenrain 9, CH-4123 Allschwil

Phone +41 61 307 80 00  
Fax +41 61 307 80 10  
[customer.center@thuba.com](mailto:customer.center@thuba.com)  
[www.thuba.com](http://www.thuba.com)